



**NOTES**

- HEIGHT OF 33KV STATION TRANSFORMER & 100KVA EARTHING TRANSFORMER WILL BE CHECKED AFTER APPROVAL OF CE/PS/PK-9.
- CLEARANCE AT 33KV SIDE BE MAINTAINED 5000mm.
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH SHEET-2 OF THIS DRAWING.

**CUSTOMER:- WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED**

**PROJECT:- WEST BENGAL TRANSMISSION SYSTEM PROJECT Pkg-9**

**TITLE:- 220/132/33KV SWITCHYARD SECTIONAL ELEVATION AT FOUNDRY PARK SUB-STATION**

**DRAWING NO.:- (0)571770-AD175(FP)-L152-002-3**

**Scale:- 1:250**

Date	19.08.11
Appr.	Dr. Anil SATTON
Norm	

Rev	Remarks	Date	Name
3	AS PER WBSETCL COMMENTS 13.12.11 SKD		
2	AS PER WBSETCL COMMENTS 02.12.11 SKD		
1	AS PER WBSETCL COMMENTS 07.10.11 SKD		

Sheet 2 OF 2  
Rev 3